



Portland Water District

FROM SEBAGO LAKE TO CASCO BAY

March 13, 2020

Brandon Binette
Northeast Civil Solutions, Inc.
381 Payne Road
Scarborough, ME 04074

Re: 287 Ocean House Road, CE
Ability to Serve with PWD Water

Dear Mr. Binette:

The Portland Water District has received your change of use request for the noted site submitted on January 15, 2020. Please see below for existing site conditions and how to proceed with your project. **Please note that this change of use determination is based on information provided. Any changes affecting the site use or water system will require further review and approval by PWD.**

Existing Site Service

The following conditions of service apply:

- Since the water demand at this site is not anticipated to change, the existing service line at this site may be used to provide domestic water to the building. Our records show that the property is currently served with a 1-inch domestic water service with a 5/8-inch meter.

The MEANS department can be reached by email at MEANS@pwd.org or by phone at (207)774-5961 Ext. 3199.

If the District can be of further assistance in this matter, please let us know.

Sincerely,
Portland Water District

Robert A. Bartels, P.E.
Senior Project Engineer

