

## TOWN OF CAPE ELIZABETH

Cape Elizabeth, Me., 23 Oct 87

Permit No. 87-716 has been granted to

Cumberland Farms to connect

Sewer at

No. ~~Scott Dyer Rd~~ 287 Ocean House Rd Street

with Public sewer in Scott Dyer Street

The connection with the sewer must be inspected, sketched on back of this card, with size and kind of pipe used, date of inspection, name of inspector, and any further information which may be of value to the department.

pc 600.00 Engineer

Tank Filled 12-13-88  
 Date of Entrance 12-22-87  
 Connected by Cumberland Farms  
 Size and kind of pipe 4" Plastic  
 Inspected by Bob Malley  
 Remarks 3' deep at end of Stub

