

3/8/2021

CapeElizabeth.org Mail - Aster Lane Turnarounds



Maureen O'Meara <maureen.omeara@capeelizabeth.org>

Aster Lane Turnarounds

1 message

Peter Gleeson <peter.gleeson@capeelizabeth.org>
To: Maureen O'Meara <maureen.omeara@capeelizabeth.org>

Mon, Mar 8, 2021 at 2:32 PM

Maureen, the turnaround located at 10 Aster Lane as constructed is adequate for fire department use. The turnaround located at 7 Aster Lane is not adequate for fire department use and has never been used by the fire department.

—

Peter Gleeson
Chief of Department
Cape Elizabeth Fire Department
2 Jordan Way
Cape Elizabeth Maine 04107
Office: (207) 767-7417
Fax: (207) 767-0681

NOTICE: Please be advised that pursuant to Title 1 M.R.S.A. Section 402(3), a public record includes any written, printed or graphic matter or any mechanical or electronic data in the possession or custody of an agency or public official that has been received or prepared for use in connection with the transaction of public or governmental business and contains information relating to the transaction of said business; therefore, the public is advised that any correspondence, whether by traditional method or e-mail with town offices or town officials, with certain limited exceptions, is public record and is available for review by any interested party.