



Alan M.
Simon

VILLAGE OF SPRING VALLEY

200 North Main Street
Spring Valley, New York 10977
Tel. (845) 352-1100 • Fax (845) 352-1164

Department of Building, Planning, and Zoning

www.villagespringvalley.org

Joseph Gross
Deputy Mayor
Samuel Smith
Trustee
Asher Grossman
Trustee
Yisroel Eisenbach
Trustee

Construction Expediting

March 19, 2025

RE: 11 Dorset Road, Spring Valley, New York 10977
Tax Map: Section 50.69, Block 1, Lot 14

Dear applicant,

Please be advised that the application for permit for the above project cannot move forward for the following reasons: the application proposes a two-family dwelling in the R-1A zoning district; which is a permitted use in the zone. The site is deficient in the following:

Maximum Floor Area Ratio of 65% allowed; 117% proposed.

We have done preliminary review of the plot plan and/or architectural plans. In addition, include the following (use the below checklist):

- ☐ Stormwater drainage system with details of catch basins, dry wells, retention basins including calculations resulting in zero net runoff. (on a separate sheet)
- ☐ Demonstrate the building height in feet.
- ☐ The location, layout, finished grade, pavement specifications and curbing proposed for parking area.
- ☐ Provide a utility plan (on a separate sheet).
- ☐ **The proposed plot plan should be submitted with separate pages in order to delineate the information provided.**
- ☐ Erosion and sedimentation control plan during and after construction, with reference to the NYS Stormwater Management Design Manual NYS DEC; as well as NY Standards and Specifications for Erosion and Sediment Control, Standards and Specifications. (on a separate sheet)
- ☐ Construction debris dumpster location
- ☐ Elevations at the centerline of the street and reference grade at the curb along the centerline of the building. Show Elevation of each proposed floor.
- ☐ Provide average grade.
- ☐ Show the floor area of each floor including the basement.
- ☐ Provide a complete application.
- ☐ Show the location of the nearest hydrant.
- ☐ Differentiate whether the structure will be **a 3-story building with basement.**
- ☐ Please provide drainage plans as well as net-zero drainage calculations for review by the Village Engineering consultants. No drywells were proposed on the plot plan.
- ☐ Topographical information to be shown and should show past the subject property into the adjacent properties.
- ☐ **The above information to be provided shown and/or corrected on the plot plan and/or architectural plans prior to appearance before the Zoning Board of Appeals.**
- ☐ **A final survey will be required prior to issuance of a Certificate of Occupancy.**
- ☐ The parking area needs to be provided with curbing.

- ☐ The parking area needs to be provided with a turnaround.
- ☐ Frame shed to be removed or a variance is required for rear and side yard setbacks.

Therefore, the application is denied. Contact the Planning and Zoning Secretary for more information. You may either correct the issues or appeal our decision by making an application to the Zoning Board of Appeals, contact the Planning and Zoning Secretary for more information.

Provide this letter to the ZBA along with your application.

If you have any questions, please feel free to contact the Department of Building, Planning and Zoning at 845-352-1100 ext. 110.

Respectfully,



Dainde Laplante C.E.O.
Zoning Administrator
CE:1001860

CC – Zoning Secretary Ann Quattrocchi

